

AIR PERMEABILITY, WATERTIGHTNESS, WIND LOAD RESISTANCE

TEST REPORT N° 10032502GM/1


Sample description	Double door aluminium French window with thermal break, one tilt-turn sash, named AL 520
Report date	03/25/2010
Applicant	ALUMINCO SA – MEGALI RACHI-INOFITA VIOTIAS 32011 ALUMINCO A.E. – ΔΙΕΛΑΣΗ ΑΛΟΥΜΙΝΙΟΥ ΘΕΣΗ ΜΕΓΑΛΗ ΡΑΧΗ-ΟΙΝΟΦΥΤΑ ΒΟΙΩΤΙΑΣ Τ.Κ.32011
Test place	The test was carried out at a testing laboratory qualified for the execution of tests in compliance with UNI EN 14351-1 standard
Laboratory qualification	date 03/26/2008

TESTS CARRIED OUT


TEST	STANDARD	CLASSIFICATION
Air Permeability	EN 12207	class 4
Watertightness	EN 12208	class AE600
Wind Load Resistance	EN 12210	class W5C

This test report 10032502GM/1 consists of n° 19 pages and 10 enclosures, and it can be reproduced only integrally

ICIM S.p.A.
ICIM Coordinator – Product area
(Giovanni Marino)



ICIM S.p.A.
ICIM Manager – Product area
(Massimiliano Florio)



ICIM S.p.A

Sede legale e operativa:
Piazza A. Diaz, 2
20123 Milano
Tel. +39 02 725341
Fax +39 02 72002098
info@icim.it – www.icim.it

Capitale Sociale
€ 260.000,00 int.vers.
C.F./P.IVA e Iscriz. Reg. Imprese di
Milano n. 12908230159
R.E.A. n. 1596292



SGQ N°004 A
SGA N°005 D
SCR N°006 F
PRD N°004 B
ISP N°046 E

Verificatore
accreditato
EMAS
IT-V-0008

