


## SUMMARY OF RESULTS

OF TESTING CERTIFICATE 08169 / 10.12.2008

<b>NUMBER</b>	<b>08169</b>	<b>DATE</b>	<b>10 / 12 / 2008</b>
---------------	--------------	-------------	-----------------------

<b>Client' s data:</b>	<b>ALUMINCO S.A.</b> <b>ALUMINIUM SYSTEMS</b> THESEI MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
<b>Product description:</b>	<b>DOUBLE SASH DOOR</b> <b>TILT / TURN</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>AL 510</b>



2202 x 1280 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 8A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C4</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOPI PAPADOPOULOU**  
**TECHNICAL MANAGER**



**IOANNIS GKERTSOS**  
**GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL