


## SUMMARY OF RESULTS OF TESTING CERTIFICATE 0813 / 22.02.2008

<b>NUMBER</b> 0813	<b>DATE</b> 22 / 02 / 2008
--------------------	----------------------------

<b>Client' s data:</b>	<b>ALUMINCO S.A.</b> ALUMINIUM SYSTEMS THESI MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
<b>Product description:</b>	<b>DOUBLE SASH WINDOW OPENING</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>AL 510</b>



1220 x 950 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 3</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class E 750</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C5</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOPI PAPAPOPOULOU**  
TECHNICAL MANAGER



**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL