

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No 16-002077-PR06

(PB-A01-02-en-01)

Client	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Double sash sliding window
Designation	System designation: AL 200
Performance-relevant product details	Material: Metal aluminium alloy – painted
Overall dimensions (W x H)	1605 mm x 2203 mm
Special features	Test sequence. Material durability and material compatibility must be taken into account. Increased operating forces.

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2016-03

EN 1027:2016-03

EN 12211:2016-03

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Instructions for use

The manufacturer is allowed to use the results obtained for preparing a Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EC. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 25 pages.

Results

Air permeability according to EN 12207:1999-11



Class 3

Watertightness according to EN 12208:1999-11



Class 3A

Resistance to wind load according to EN 12210:2016-03



Class C1/B2

ift Rosenheim

15.12.2016

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Construction Product Testing

Martin Beger, Dipl.-Ing. (FH)
Operating Testing Officer
Construction Product Testing