

ift-Nachweis

Classification Report



Nummer	17-003792-PR01 (NW-A01-0203-en-01)
Inhaber	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Produkt	Single sash lifting-sliding door with fixed sidelight
Bezeichnung	System: SL2450 Shipping name: SL2450 - Sliding System
Details	Manufacturer ALUMINCO S.A., - Inofita Viotias; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction To the right (seen from inside); Overall dimensions (W x H) 2000 mm x 2200 mm
Besonderheiten	Test sequence

Ergebnis

Operating forces according to EN 13115:2001-07



Class: 1

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: 3A

ift Rosenheim

23.02.2018

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing

Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Grundlagen *)

EN 14351-1:2006+A2:2016-09
*) und entsprechende nationale Fassungen
(z.B. DIN EN)

Prüfbericht: 17-003792-PR01 PB-
A01-0203-en-01

Darstellung



Verwendungshinweise

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Gültigkeit

Zeitlich nicht limitiert.

Bei der Anwendung sind die Aktualität der Grundlagen sowie die Übereinstimmung des Produkts zu beachten.

Veröffentlichungshinweise

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identitäts-Check



www.ift-rosenheim.de/ift-geprueft
ID: 7E3-2E8BB