

Classification Report

Number	18-002284-PR02 (NW-A01-0203-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Double tilt and turn casement door with opening central meeting stile
Designation	Shipping name: W4750
Details	Manufacturer ALUMINCO S.A., - Inofita Viotias; Material Aluminium system with thermal break; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to the inside, Inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 1400 mm x 2200 mm
Special features	Test sequence. Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C2/B2

Watertightness according to EN 12208:1999-11



Class: 3A

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 18-002284-PR02 PB-A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
17.08.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: AA1-9BF29