


## SUMMARY OF RESULTS

OF TESTING CERTIFICATE 0949 / 21.04.2009

NUMBER	0949	DATE	21 / 04 / 2009
--------	------	------	----------------

Client' s data:	<b>ALUMINCO S.A.</b> <b>ALUMINIUM SYSTEMS</b> THESI MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
Product description:	<b>DOUBLE SASH DOOR</b> <b>SLIDING</b>
Material:	<b>ALUMINIUM</b>
System :	<b>AL 220</b>



2220 x 1440 mm

<b>Air Permeability</b> ELOT EN 1026:2000 / ELOT EN 12207:2000	<b>Class 2</b>
<b>Watertightness</b> ELOT EN 1027:2000 / ELOT EN 12208:2000	<b>Class 1A</b>
<b>Resistance to Wind Load</b> ELOT EN 12211:2000 / ELOT EN 12210:2000	<b>Class C3</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOPI PAPAPOULOU**  
TECHNICAL MANAGER



**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL